

## TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

**OBJECT** Single-core power cable

**TYPE** 18/30(36) kV, 1x630 mm<sup>2</sup>, A2XWcWaY(P) XLPE

<b>Rated voltage, U<sub>0</sub>/U (U<sub>m</sub>)</b>	<b>18/30 (36) kV</b>	<b>Conductor material</b>	<b>Al</b>
<b>Conductor cross-section</b>	<b>1x630 mm<sup>2</sup></b>	<b>Insulation material</b>	<b>XLPE</b>

**MANUFACTURER** KEC INTERNATIONAL LIMITED,  
Vadodara, Gujarat, India

**CLIENT** KEC INTERNATIONAL LIMITED,  
Vadodara, Gujarat, India

**TESTED BY** KEMA Nederland B.V.,  
Arnhem, The Netherlands

**DATE(S) OF TESTS** 10 October to 22 November 2013

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate, has been subjected to the series of proving tests in accordance with

### **IEC 60502-2** (2005)

This Type Test Certificate has been issued by KEMA following exclusively the STL Guides.

**The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performances are considered to comply with the above Standard and to justify the ratings assigned by the manufacturer as listed on page 4 to 6.**

This Certificate applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the manufacturer.

This Certificate consists of 34 pages in total.

**Copyright: Only integral reproduction of this Certificate is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this Certificate may be available and have the status "for information only". The sealed and bound version of the Certificate is the only valid version.**

KEMA Nederland B.V.



S.A.M. Verhoeven  
Director Testing, Inspections &  
Certification The Netherlands

Arnhem, 18 December 2013

## CONTENTS

page

1	Identification of the object tested .....	4
1.1	Ratings/characteristics of the object tested and proved by tests.....	4
1.2	Description of the object tested.....	4
1.3	List of drawings .....	6
2	General information .....	7
2.1	The tests were witnessed by.....	7
2.2	The tests were carried out by.....	7
2.3	Subcontracting .....	7
2.4	Purpose of the tests .....	7
2.5	Measurement uncertainty .....	7
3	Electrical type tests .....	8
3.1	Test arrangement.....	8
3.1.1	Determination of the cable conductor temperature.....	8
3.1.2	Photograph of test set-up.....	9
3.2	Bending test .....	10
3.3	Partial discharge test .....	11
3.4	Tan $\delta$ measurement.....	12
3.5	Heating cycle test.....	13
3.5.1	Heating cycles.....	13
3.5.2	Partial discharge test .....	14
3.6	Impulse test followed by a voltage test .....	15
3.6.1	Impulse test.....	15
3.6.2	Voltage test .....	18
3.7	Voltage test for 4 h .....	18
3.8	Resistivity of semi-conducting screens .....	19
4	Non-electrical type tests.....	20
4.1	Measurement of thickness of insulation.....	20
4.2	Measurement of thickness of non-metal sheaths (including extruded separation sheaths, but excluding inner coverings) .....	21
4.3	Tests for determining the mechanical properties of insulation before and after ageing .....	22
4.4	Tests for determining the mechanical properties of non-metallic sheaths before and after ageing .....	23
4.5	Additional ageing test on pieces of completed cable.....	24
4.6	Loss of mass test on PVC sheaths of type ST <sub>2</sub> .....	25
4.7	Pressure test at high temperature on non-metallic sheaths .....	26
4.8	Test on PVC sheaths at low temperature .....	27
4.9	Test on PVC sheaths to cracking (heat shock test).....	28
4.10	Hot set test for XLPE insulation .....	29
4.11	Water absorption test on insulation.....	29
4.12	Flame spread on single cables .....	30
4.13	Shrinkage test for XLPE insulation .....	31
4.14	Strippability test for insulation screen .....	31

5	Check of cable construction .....	32
6	Drawings .....	33
7	Measurement uncertainty .....	34

## 1 IDENTIFICATION OF THE OBJECT TESTED

### 1.1 Ratings/characteristics of the object tested and proved by tests

Rated voltage, $U_0/U$ ( $U_m$ )	18/30 (36) kV
Rated maximum conductor temperature in normal operation	90 °C
Rated conductor cross-section	1x630 mm <sup>2</sup>

The test voltages were based on  $U_0$  test = 18 kV.

### 1.2 Description of the object tested

Standard	IEC 60502-2, Clause 5-14
Manufacturer (as stated by the client)	KEC INTERNATIONAL LIMITED, Vadodara, Gujarat, India
Type	$U_0$ = 18 kV 1x630 mm <sup>2</sup> XLPE CABLE
Manufacturing date	2013
Sampling procedure	By the manufacturer
Quantity submitted	65 m
Rated voltage, $U_0/U$ ( $U_m$ )	18/30 (36) kV
Nominal capacitance between conductor and metal screen	0,355 µF/km
No. of cores (core identification)	1
Overall diameter	65,5 mm
Embossing on the oversheath	KEC INTL.LTD. RPG CABLES 18/30(36)kV ELECTRIC CABLE 1x630mm <sup>2</sup> A2XWCWaY(P) XLPE ELECTRICITY Co. OF GHANA LTD (ECG) 2013
Construction	see List of drawings

#### Conductor

– material	Aluminium
– cross-section	630 mm <sup>2</sup>
– nominal diameter	29,8 mm
– type	Stranded compacted
– maximum conductor temperature in normal operation	90 °C
– presence and nature of measures to achieve longitudinal watertightness	No

#### Conductor screen

– material	Semi-conducting compound 33 kV
– nominal thickness	0,6 mm
– material designation	DYM 515
– manufacturer of the material	DYM, South Korea

### Insulation

– material	TR-XLPE
– nominal thickness	8 mm
– material designation	Dow Endurance (TM) HFDB 4202 EC
– manufacturer of the material	DOW CHEMICALS

### Insulation (core) screen

– material	Semi conducting compound 33 kV
– strippable	Yes
– nominal thickness	0,6 mm
– material designation	Pramkor 3005 ES
– manufacturer of the material	Pramkor

### Metallic screen

– material	Copper tape, 1 layer, and wires
– number of wires	70
– nominal diameter of wires	0,8 mm
– nominal thickness and width of tape	10 x 0,1 mm (Counter Helix)
– cross-sectional area	35 mm <sup>2</sup>
– diameter over metallic screen	49,8 mm

### Longitudinally watertightness

– presence and nature of measures to achieve longitudinal watertightness along insulation screen	None
--	------

### Separation sheath

– material	PVC, type ST <sub>2</sub>
– nominal thickness	1,6 mm
– manufacturer of the material	YASH POLYMERS

### Metallic armour

– material	Aluminium wires
– number of wires	59
– nominal diameter of wires	2,5 mm
– cross-sectional area	289,4 mm <sup>2</sup>
– manufacturer of the material	VEDANTA ALUMINIUM

#### Oversheath

- material PVC, type ST<sub>2</sub>
- nominal thickness 3,0 mm
- nominal overall diameter of the cable (D) 63 mm
- manufacturer of the material YASH POLYMERS
- colour Blue
- graphite coating applied No

**Fire retardant** (according to IEC 60332-1) No

#### Manufacturing details insulation system

- location of manufacturing Vadodra, Gujarat, India
- type of extrusion line CCV
- type of extrusion Triple extrusion
- factory identification of extrusion line EPL-50 Malliffer
- manufacturer of the extrusion line Maillifer, Finland
- identification of production batch Cable UID no.2868
- curing means Dry curing
- cooling means Dry cured water cooled
- manufacturing length (where cable sample for testing has been taken from) 600 m
- length markings on cable sample sent to KEMA begin: 0002 m, end: 0067m

### 1.3 List of drawings

The manufacturer has guaranteed that the object submitted for tests has been manufactured in accordance with the following drawing and/or document. KEMA has verified that this drawing and/or document adequately represents the object tested. The manufacturer is responsible for the correctness of this drawing and/or document and the technical data presented.

The following drawing and/or document has been included in this Certificate:

Drawing no./document no.	Revision
XLPE/1/Wa	Rev.0

## 2 GENERAL INFORMATION

### 2.1 The tests were witnessed by

The tests were carried out without a representative of the client present.

### 2.2 The tests were carried out by

Name	Company
Mr A. Sengers	KEMA Nederland B.V.,
Mr E. Pultrum	Arnhem, The Netherlands

### 2.3 Subcontracting

The following tests were subcontracted to DNV KEMA New Energy Technology (NET):

- measurement of resistivity of semi-conducting screens in accordance with Sub clause 18.1.9.
- non-electrical type tests in accordance with Clause 19.
- check of cable constructions in accordance with clauses 5-14 of IEC 60502-2.

### 2.4 Purpose of the tests

Purpose of the tests was to verify whether the material complies with the specified requirements.

### 2.5 Measurement uncertainty

A table with measurement uncertainties is enclosed in this {Certificate\report}. Unless otherwise stated, the measurement uncertainties of the results presented in this {Certificate\report} are as indicated in that table.

### **3 ELECTRICAL TYPE TESTS**

#### **3.1 Test arrangement**

##### **3.1.1 Determination of the cable conductor temperature**

###### **Standard**


Standard IEC 60840, Annex A, Subclause A.3.1 was used as a guide

For the tests at elevated temperature, a reference loop for temperature control of the conductor was installed and conductor current was used for heating. The reference cable was cut from the total cable length intended for the type test. This reference loop was installed close to the test loop in order to create the same environmental conditions, thus the conductor temperature of the reference loop is representative for the conductor temperature of the test loop. IEC 60840, Annex A was used as a guide and IEC 60840, Subclause A.3.1, method 1 was applied.

The tests at elevated temperature are carried out two hours after thermal equilibrium has been established.



### 3.1.2 Photograph of test set-up



### 3.2 Bending test

#### Standard and date

Standard IEC 60502-2, Subclause 18.1.3

Test date 10 October 2013

#### Environmental conditions

Ambient temperature 12 °C

#### Characteristic test data

Temperature of test object 12 °C

Required bending diameter  $20(d + D) + 5\%$

Length of cable bended 21 m

Length marking of cable bended 29 - 50

Actual external diameter of cable $D$ (mm)	Actual diameter of conductor $d$ (mm)	Required bending diameter $D_r$ (mm)	Diameter of test cylinder $D_t$ (mm)
65,5	29,8	$1811 \leq D_r \leq 2001$	1900

#### Result

The test was carried out successfully

### 3.3 Partial discharge test

#### Standard and date

Standard IEC 60502-2, Subclause 18.1.4

Test date 15 October 2013

#### Environmental conditions

Ambient temperature 22 °C

#### Characteristic test data

Temperature of test object 22 °C

Circuit direct

Calibration 5 pC

Noise level at 1,73  $U_0$  < 2 pC

Sensitivity 4 pC

Required sensitivity ≤ 5 pC

Centre frequency 140 kHz

Bandwidth 100 kHz

Test frequency 50 Hz

Coupling capacitor 2600 pF

Core	Voltage applied, 50 Hz		Duration (s)	Partial discharge level (pC)
	... x $U_0$	(kV)		
1	2	36	10	-
	1,73	31,1	-	Not detectable

#### Requirement

There shall be no detectable discharge exceeding the declared sensitivity from the test object at 1,73  $U_0$ .

#### Result

The object passed the test.

### 3.4 Tan $\delta$ measurement

#### Standard and date

Standard IEC 60502-2, Subclause 18.1.5

Test date 16 October 2013

#### Environmental conditions

Ambient temperature 21 °C

#### Characteristic test data

Temperature of test object 97 °C

Length of test object 21,0 m

Standard capacitor 100 pF

Core	Voltage applied, 50 Hz (kV)	Capacitance of core <sup>1)</sup> ( $\mu$ F/km)	Tan $\delta$
1	5	0,228	$1,2 \times 10^{-4}$
<sup>1)</sup> for information only			

#### Requirement

The measured value shall not be higher than  $40 \times 10^{-4} \geq 2$  kV.

#### Result

The object passed the test.

### 3.5 Heating cycle test

#### 3.5.1 Heating cycles.

##### Standard and date

Standard IEC 60502-2, Subclause 18.1.6

Test dates 17 to 25 October 2013

##### Environmental conditions

Ambient temperature 20 °C

##### Characteristic test data

Heating method conductor current

Stabilized temperature 97 °C

No. of heating cycles	Required steady conductor temperature (°C)	Heating current during steady condition (A)	Heating cycle		Cooling cycle
			Total duration (h)	Duration of conductor at steady temperature (h)	Total duration (h)
20	95-100	approx. 1150	5	2	4

##### Result

The test was carried out successfully.

### 3.5.2 Partial discharge test

#### Standard and date

Standard IEC 60502-2, Subclause 18.1.4  
Test date 25 October 2013

#### Environmental conditions

Ambient temperature 20 °C

#### Characteristic test data

Temperature of test object 24 °C  
Circuit direct  
Calibration 5 pC  
Noise level at 1,73 U<sub>0</sub> < 2 pC  
Sensitivity 4 pC  
Required sensitivity ≤ 5 pC  
Centre frequency 107 kHz  
Bandwidth 100 kHz  
Test frequency 50 Hz  
Coupling capacitor 2600 pF

Core	Voltage applied, 50 Hz		Duration (s)	Partial discharge level (pC)
	... x U <sub>0</sub>	(kV)		
1	2	36	10	-
	1,73	31,1	-	Not detectable

#### Requirement

There shall be no detectable discharge exceeding the declared sensitivity from the test object at 1,73 U<sub>0</sub>.

#### Result

The object passed the test.

### 3.6 Impulse test followed by a voltage test

#### 3.6.1 Impulse test

##### Standard and date

Standard IEC 60502-2, Subclause 18.1.7

Test date 25 October 2013

##### Environmental conditions

Ambient temperature 21 °C

##### Characteristic test data

Temperature of test object 97 °C

Specified test voltage 170 kV

Testing arrangement		Polarity	Voltage applied (% of test voltage)	No. of impulses	See figure on next pages
Voltage applied to	Earthed				
Conductor	Metal screens	Positive	50	1	1 (waveshape)
			65	1	2
			80	1	2
			100	10	3 and 4
Conductor	Metal screens	Negative	50	1	5 (waveshape)
			65	1	6
			80	1	6
			100	10	7 and 8

##### Requirement

Each core of the cable shall withstand without failure 10 positive and 10 negative voltage impulses.

##### Result

The object passed the test.



## Lightning impulse test with positive voltage




Fig. 1: Waveshape 72122084, KEC, +50% of test voltage




Fig. 2: 72122084, KEC, +65% and +80% of test voltage




Fig. 3: 72122084, KEC, +100% of test voltage




Fig. 4: 72122084, KEC, +100% of test voltage



## Lightning impulse test with negative voltage



Fig. 5: Waveshape 72122084, KEC, -50% of test voltage




Fig. 6: 72122084, KEC, -65% and -80% of test voltage




Fig. 7: 72122084, KEC, -100% of test voltage




Fig. 8: 72122084, KEC, -100% of test voltage

### 3.6.2 Voltage test

#### Standard and date

Standard IEC 60502-2, Subclause 18.1.7  
Test date 28 October 2013

#### Environmental conditions

Ambient temperature 20 °C

#### Characteristic test data

Temperature of test object 20 °C

Testing arrangement		Voltage applied, 50 Hz		Duration (min)
Voltage applied to	Earth connected to	... x U <sub>0</sub>	(kV)	
Conductor	Metal screens	3,5	63	15

#### Requirement

No breakdown of the insulation shall occur.

#### Result

The object passed the test.

### 3.7 Voltage test for 4 h

#### Standard and date

Standard IEC 60502-2, Subclause 18.1.8  
Test date 28 October 2013

#### Environmental conditions

Ambient temperature 20 °C

#### Characteristic test data

Temperature of test object 20 °C

Testing arrangement		Voltage applied, 50 Hz		Duration (h)
Voltage applied to	Earth connected to	... x U <sub>0</sub>	(kV)	
Conductor	Metal screens	4	72	4

#### Requirement

No breakdown of the insulation shall occur.

#### Result

The object passed the test.

### 3.8 Resistivity of semi-conducting screens

**Standard and date**

Standard IEC 60502-2, Subclause 18.1.9

Test date 21 November 2013

**Characteristic test data**

Temperature during ageing 100 °C

Duration 7 days

Resistivity measured at  $90 \pm 2$  °C

Item	Unit	Requirement	Measured/determined
Conductor screen			
-without ageing	$\Omega\text{m}$	$\leq 1000$	0,40
-after ageing	$\Omega\text{m}$	$\leq 1000$	0,90
Insulation screen			
-without ageing	$\Omega\text{m}$	$\leq 500$	2,81
-after ageing	$\Omega\text{m}$	$\leq 500$	3,21

**Result**

The object passed the test

## 4 NON-ELECTRICAL TYPE TESTS

### 4.1 Measurement of thickness of insulation

#### Standard and date

Standard IEC 60502-2, Subclause 19.1

Test date 19 November 2013

Item	Unit	Requirement	Specified	Measured/determined
Nominal	mm	-	8,00	8,00
Average	mm	-	-	7,82
Minimum [ $t_{\min}$ ]	mm	$\geq 7,1$	$\geq 7,1$	7,58
Maximum [ $t_{\max}$ ]	mm	-	-	8,00
$(t_{\max} - t_{\min}) / t_{\max}$	-	$\leq 0,15$	-	0,05

#### Result

The object passed the test.

## 4.2 Measurement of thickness of non-metal sheaths (including extruded separation sheaths, but excluding inner coverings)

### Standard and date

Standard IEC 60502-2, Subclause 19.2

Test date 8 November 2013

### Separation sheath thickness

Thickness	Unit	Requirement	Specified	Measured/determined
Nominal	mm	$\geq 1,2$	1,6	-
Average	mm	-	-	1,50
Minimum	mm	$\geq 1,08$	$\geq 1,08$	1,29

### Oversheath thickness

Thickness	Unit	Requirement	Specified	Measured/determined
Nominal	mm	$\geq 1,8$	3,0	-
Average	mm	-	-	2,35
Minimum	mm	$\geq 2,20$	$\geq 2,20$	2,23

### Result

The object passed the test.

#### 4.3 Tests for determining the mechanical properties of insulation before and after ageing

##### Standard and date

Standard IEC 60502-2, Subclause 19.3

Test date 1 to 7 November 2013

##### Characteristic test data

Temperature during aging  $135 \pm 3 \text{ }^{\circ}\text{C}$

Ageing duration 7 days

Item	Unit	Requirement	Measured/determined
<b>Without ageing</b>			
Tensile strength	N/mm <sup>2</sup>	$\geq 12,5$	32,8
Elongation at break	%	$\geq 200$	735
<b>After ageing in air oven</b>			
Tensile strength			
value after ageing	N/mm <sup>2</sup>	-	32,0
variation	%	$\pm 25 \text{ max.}$	-2
Elongation at break			
value after ageing	%	-	638
variation	%	$\pm 25 \text{ max.}$	-13

##### Result

The object passed the test.

#### 4.4 Tests for determining the mechanical properties of non-metallic sheaths before and after ageing

##### Standard and date

Standard IEC 60502-2, Subclause 19.4

Test date 2 to 8 November 2013

##### Characteristic test data

Temperature during aging  $100 \pm 2 \text{ }^{\circ}\text{C}$

Ageing duration 7 days

##### Separation sheath

Item	Unit	Requirement	Measured/determined
<b>Without ageing</b>			
Tensile strength	N/mm <sup>2</sup>	$\geq 12,5$	15,3
Elongation at break	%	$\geq 150$	194
<b>After ageing in air oven</b>			
Tensile strength			
value after ageing	N/mm <sup>2</sup>	$\geq 12,5$	16,2
variation	%	$\pm 25 \text{ max.}$	6
Elongation at break			
value after ageing	%	$\geq 150$	171
variation	%	$\pm 25 \text{ max.}$	-12

##### Oversheath

Item	Unit	Requirement	Measured/determined
<b>Without ageing</b>			
Tensile strength	N/mm <sup>2</sup>	$\geq 12,5$	16,4
Elongation at break	%	$\geq 150$	164
<b>After ageing in air oven</b>			
Tensile strength			
value after ageing	N/mm <sup>2</sup>	$\geq 12,5$	15,2
variation	%	$\pm 25 \text{ max.}$	-7
Elongation at break			
value after ageing	%	$\geq 150$	154
variation	%	$\pm 25 \text{ max.}$	-6

##### Result

The object passed the test.

#### 4.5 Additional ageing test on pieces of completed cable

##### Standard and date

Standard IEC 60502-2, Subclause 19.5

Test date 1 to 8 November 2013

##### Characteristic test data

Temperature during aging  $100 \pm 2 \text{ }^{\circ}\text{C}$

Ageing duration 7 days

##### Insulation

Item	Unit	Requirement	Measured/determined
Tensile strength			
value after ageing	N/mm <sup>2</sup>	-	31,4
variation	%	$\pm 25 \text{ max.}$	-4
Elongation at break			
value after ageing	%	-	701
variation	%	$\pm 25 \text{ max.}$	-5

##### Separation sheath

Item	Unit	Requirement	Measured/determined
Tensile strength			
value after ageing	N/mm <sup>2</sup>	$\geq 12,5$	15,6
variation	%	$\pm 25 \text{ max.}$	3
Elongation at break			
value after ageing	%	$\geq 150$	199
variation	%	$\pm 25 \text{ max.}$	2

##### Oversheath

Item	Unit	Requirement	Measured/determined
Tensile strength			
value after ageing	N/mm <sup>2</sup>	$\geq 12,5$	15,8
variation	%	$\pm 25 \text{ max.}$	-4
Elongation at break			
value after ageing	%	$\geq 150$	194
variation	%	$\pm 25 \text{ max.}$	18

##### Result

The object passed the test.



#### 4.6 Loss of mass test on PVC sheaths of type ST<sub>2</sub>

**Standard and date**

Standard IEC 60502-2, Subclause 19.6

Test dates 1 to 8 November 2013

**Characteristic test data**

Temperature treatment 100 ± 2 °C

Duration 7 days

**Inner sheath/separation sheath**

Item	Unit	Requirement	Measured/determined
Loss of mass	mg/cm <sup>2</sup>	≤ 1,5	0,99

**Oversheath**

Item	Unit	Requirement	Measured/determined
Loss of mass	mg/cm <sup>2</sup>	≤ 1,5	0,82

**Result**

The object passed the test.

#### 4.7 Pressure test at high temperature on non-metallic sheaths

##### Standard and date

Standard IEC 60502-2, Subclause 19.7

Test dates 6 to 8 November 2013

##### Characteristic test data PVC ST<sub>2</sub> (separation sheath)

Temperature 90 ± 2 °C

Heating time 6 hours

Load 8,8 N

##### Separation sheath

Item	Unit	Requirement	Measured/determined
Depth of indentation	%	≤ 50	36,4

##### Characteristic test data PVC ST<sub>2</sub> (separation sheath)

Temperature 90 ± 2 °C

Heating time 6 hours

Load 12,1 N

##### Oversheath

Item	Unit	Requirement	Measured/determined
Depth of indentation	%	≤ 50	36,3

##### Result

The object passed the test.

#### 4.8 Test on PVC sheaths at low temperature

**Standard and date**

Standard IEC 60502-2, Subclause 19.8

Test dates 8 to 19 November 2013

**Characteristic test data PVC ST2**Temperature  $-15 \pm 2$  °CCooling time  $\geq 16$  h

Mass of hammer 1250 g

**Separation sheath**

Item	Unit	Requirement	Measured/determined
Cold elongation test	%	$\geq 20$	50
Cold impact test	-	No cracks	No cracks

**Oversheath**

Item	Unit	Requirement	Measured/determined
Cold elongation test	%	$\geq 20$	32
Cold impact test	-	No cracks	No cracks

**Result**

The object passed the test.

#### 4.9 Test on PVC sheaths to cracking (heat shock test)

##### Standard and date

Standard IEC 60502-2, Subclause 19.9

Test date 7 November 2013

##### Characteristic test data

Temperature  $150 \pm 3 \text{ }^{\circ}\text{C}$   
Duration 1 h  
Diameter of mandrel 4 mm  
Number of turns 6

##### Separation sheath

Item	Unit	Requirement	Measured/determined
Visual examination	-	No cracks	No cracks

##### Characteristic test data

Temperature  $150 \pm 3 \text{ }^{\circ}\text{C}$   
Duration 1 h  
Diameter of mandrel 6 mm  
Number of turns 6

##### Oversheath

Item	Unit	Requirement	Measured/determined
Visual examination	-	No cracks	No cracks

##### Result

The object passed the test.

#### 4.10 Hot set test for XLPE insulation

##### Standard and date

Standard IEC 60502-2, Subclause 19.11

Test date 5 November 2013

##### Characteristic test data

Air temperature  $200 \pm 3$  °C  
Time under load 15 min  
Mechanical stress  $20 \text{ N/cm}^2$

##### Insulation

Item	Unit	Requirement	Measured/determined
Elongation under load	%	$\leq 175$	48
Permanent elongation after cooling	%	$\leq 15$	-1

##### Result

The object passed the test.

#### 4.11 Water absorption test on insulation

##### Standard and date

Standard IEC 60502-2, Subclause 19.13

Test dates 4 to 22 November 2013

##### Characteristic test data XLPE

Temperature of water  $85 \pm 2$  °C  
Duration 336 h  
Test method Gravimetric

##### Insulation

Item	Duration (h)	Requirement	Measured/determined
Increase of mass	mg/cm <sup>2</sup>	$\leq 1$	0,03

##### Result

The object passed the test.

#### 4.12 Flame spread on single cables

##### Standard and date

Standard IEC 60502-2, Subclause 19.14

Test date 11 November 2013

##### Characteristic test data

Overall diameter of test piece 124,84 mm

Time for flame application 480 s

Flame type 1 kW pre-mixed flame

Complete cable	Unit	Requirement	Measured/determined
The distance between the lower edge of the top support and the onset of charring	mm	$\geq 50$	352
The distance between the lower edge of the top support and charring extends downwards to a point	mm	$\leq 540$	503

##### Result

The object passed the test.

#### 4.13 Shrinkage test for XLPE insulation

##### Standard and date

Standard IEC 60502-2, Subclause 19.16

Test date 5 November 2013

##### Characteristic test data

Temperature  $130 \pm 3 \text{ }^{\circ}\text{C}$

Duration 1 h

Distance L between marks 200 mm

##### Insulation XLPE

Item	Unit	Requirement	Measured/determined
Shrinkage	%	$\leq 4$	2,4

##### Result

The object passed the test.

#### 4.14 Strippability test for insulation screen

##### Standard and date

Standard IEC 60502-2, Subclause 19.21

Test date 18 November 2013

Item	Unit	Requirement	Measured/determined
Before ageing	N	$4 \leq F \leq 45$	19 – 16 – 20
After ageing	N	$4 \leq F \leq 45$	11 – 13 – 15

##### Result

The object passed the test.

## 5 CHECK OF CABLE CONSTRUCTION

### Standard and date

Standard IEC 60502-2, Subclause 5-14

Test dates 7 to 19 November 2013


Item	Unit	Requirement	Specified	Measured/determined
<b>Conductor</b>				
Diameter of conductor (d)	mm	$28,7 \leq d \leq 32,5$	29,8	29,78
Number of wires	-	$\geq 53$	-	55
Diameter of wires	mm	-	-	3,27
Swelling yarns applied	-	-	-	-
Resistance at 20 °C	$\Omega/\text{km}$	$\leq 0,0469$	-	0,04645
<b>Conductor screen</b>				
Diameter over conductor screen	mm	-	-	31,21
Thickness	mm	-	$\geq 0,3$	0,74
<b>Insulation</b>				
Diameter over insulation	mm	-	-	47,08
Thickness	mm	$\geq 7,1$	8,0	7,82
<b>Insulation screen</b>				
Diameter over insulation screen	mm	-	-	49,68
Thickness	mm	-	$\geq 0,3$	0,72
<b>Copper screen</b>				
Number of wires	-	-	70	70
Diameter of Cu wires	mm	-	0,8	0,84
<b>Binder tape (copper tape)</b>				
Thickness x width of tape	mm	-	0,10 x 10	0,11 x 9,92
<b>Separation sheath</b>				
Diameter over separation sheath	mm	-	-	52,84
Thickness	mm	$\geq 1,08$	$\geq 1,08$	1,50
<b>Metallic armour</b>				
Number of wires	-	-	59	60
Diameter of wires	mm	-	2,50	2,49
Binder tape thickness x width	mm	-	-	0,10 x 63,23
Gap between wires	mm	-	-	8,54
<b>Oversheath</b>				
Diameter over oversheath	mm	-	63,00	64,62
Thickness	mm	$\geq 2,20$	$\geq 2,20$	2,35
Colour	-	-	blue	blue
Embossing on the cable	KEC INTL. LTD RPG CABLES 18-30(36)kV ELECTRIC CABLE 1x630mm <sup>2</sup> A2XWCWaY(P)XLPE ELECTRICITY Co OF GHANA LTD (ECG) 2013			

### Result

The object passed the test.



6 DRAWINGS



## 7 MEASUREMENT UNCERTAINTY

The measurement uncertainties in the results presented are as specified below unless otherwise indicated.

Measurement	Measurement uncertainty
Dielectric tests and impulse current tests:	
– peak value	$\leq 3\%$
– time parameters	$\leq 10\%$
Capacitance measurement	0,3%
Tan $\delta$ measurement	$\pm 0,5\% \pm 5 \times 10^{-5}$
Partial discharge measurement:	
– $< 10$ pC	2 pC
– 10 to 100 pC	5 pC
– $> 100$ pC	20%
Measurement of impedance AC-resistance measurement	$\leq 1\%$
Measurement of losses	$\leq 1\%$
Measurement of insulation resistance	$\leq 10\%$
Measurement of DC resistance:	
– 1 to 5 $\mu\Omega$	1%
– 5 to 10 $\mu\Omega$	0,5%
– 10 to 200 $\mu\Omega$	0,2%
Radio interference test	2 dB
Calibration of current transformers	$2,2 \times 10^{-4} I_i/I_u$ and 290 $\mu\text{rad}$
Calibration of voltage transformers	$1,6 \times 10^{-4} U_i/U_u$ and 510 $\mu\text{rad}$
Measurement of conductivity	5%
Measurement of temperature:	
– -50 to -40 °C	3 K
– -40 to 125 °C	2 K
– 125 to 150 °C	3 K
Tensile test	1%
Sound level measurement	type 1 meter as per IEC 60651 and ANSI S1,4,1971
Measurement of voltage ratio	0,1%